

# CAMS

## TUBING REQUIREMENTS FROM THE AIRFLOW MEASURING PROBE ARRAY TO THE CAMS ENCLOSURE

**TUBING LAYOUT**

'D' = DISTANCE FROM FURTHEST PROBE TO CONNECTION FITTINGS ON CAMS ENCLOSURE

ITEM	DISTANCE 'D'		
	< 25 FT.	25 - 50 FT.	> 50 FT.
1	1/2" TUBE	1/2" TUBE	1/2" TUBE
2	1/2" TUBE	3/4" TUBE	3/4" TUBE
3	1/2" TUBE	3/4" TUBE	1" TUBE
4	1/2" MPT X 1/2" COMP. ELBOW	1/2" MPT X 1/2" COMP. ELBOW	1/2" MPT X 1/2" COMP. ELBOW
5	1/2" COMP. ELBOW	SEE FIGURE 'A' 3/4" COMP. X 3/4" FPT ELBOW & 3/4" MPT X 1/2" COMP. ADAPTER	SEE FIGURE 'A' 3/4" COMP. X 3/4" FPT ELBOW & 3/4" MPT X 1/2" COMP. ADAPTER
6	1/2" COMP. TEE	SEE FIGURE 'B' 3/4" COMP. X 3/4" FPT BRANCH TEE & 3/4" MPT X 1/2" COMP. ADAPTER	SEE FIGURE 'B' 3/4" COMP. X 3/4" FPT BRANCH TEE & 3/4" MPT X 1/2" COMP. ADAPTER
7	1/2" COMP. TEE	3/4" COMP. TEE	SEE FIGURE 'B' 3/4" COMP. X 3/4" FPT BRANCH TEE & 3/4" MPT X 1" COMP. ADAPTER
8	1/2" MPT X 1/2" COMP. ADAPTER	1/2" MPT X 3/4" COMP. ADAPTER	1/2" MPT X 1" COMP. ADAPTER

**RECOMMENDED TUBING WALL THICKNESS**  
.035" WALL TUBING IS SUITABLE FOR COMPRESSION FITTINGS. IF SOCKET WELD FITTINGS ARE SUBSTITUTED, INCREASE WALL THICKNESS TO .065".

FIGURE 'A'

FIGURE 'B'

P.O. Box 6358, Santa Rosa, CA 95406 (707) 544-2706  
 www.airmonitor.com amcsales@airmonitor.com

