CAMS - High Capacity with Rapid Stop COMBUSTION AIRFLOW MANAGEMENT SYSTEM

STANDARD CONSTRUCTION ■ Brass and Copper Construction All wetted tubing, fittings and valves constructed of brass and/or copper. Enclosure is NEMA 4 painted steel. External connection fittings are stainless steel FPT. ■ Stainless Steel Construction All wetted tubing, fittings and valves constructed of 316 stainless steel. Enclosure is NEMA 4 painted steel. External connection fittings are stainless steel FPT. **OPTIONAL CONSTRUCTION** ■ NEMA 4X stainless steel enclosure **Power Supply** In Rush Hold ☐ EMC Rated NEMA 4X stainless steel enclosure □ 24VAC 225VA 123VA ☐ Vortex Cooler (requires 80-150 max. psig air supply) * ☐ 24VDC 61W 61W ☐ Heater (requires 120VAC power supply) ** ☐ 120VAC 282VA 155VA ■ Purge start and/or purge interrupt pushbuttons □ Panel mounted □ Door mounted * Add 2 watts @ 24-99V / 50-60Hz/DC for 400 BTUH @ 100 psig \leq 70°F ** Add 1.7A @ 120VAC for 200 watt heater ☐ Viewing window on door (not available with EMC option) DIMENSIONAL INFORMATION (Note: Refer to custom submittal drawings for work order specific details.) **OPTIONAL PURGE START** Ø.44 30.00 AND PURGE INTERRUPT **INSULATION** (TYP) 24.00 FOR USE WITH **PUSHBUTTONS OPTIONAL** VORTEX COOLER OR **OPTIONAL HEATER** 0 0 **OPTIONAL AVERAGING** BOARD, **TEMPERATURE** 8 TRANSMITTER, 36. 37. TRANSFORMER **OPTIONAL HFATFR OPTIONAL** INTERIOR VIEW INTERIOR VIEW **VORTEX COOLER** (W/OPTIONAL COOLER) (W/OPTIONAL HEATER) CONNECTION CODE: A. STATIC PRESSURE (LO) SIGNAL FROM FLOW ELEMENT 3/4" (F)NPT B. TOTAL PRESSURE (HI) SIGNAL FROM FLOW ELEMENT 3/4" (F)NPT ô C. SUPPLY AIR 80-150 MAX. PSIG 3/4" (F)NPT 8.00 F. VORTEX COOLER AIR SUPPLY N/A нШ G. VORTEX COOLER MOUNTING HOLE N/A H. VORTEX COOLER ENCLOSURE VENT N/A 1/2" CONDUIT SEAL J. ELECTRICAL CONNECTION POWER WIRING **BOTTOM VIEW** K. ELECTRICAL CONNECTION SIGNAL WIRING 1/2" CONDUIT SEAL L. STATIC PRESSURE RAPID STOP VENT N/A M. TOTAL PRESSURE RAPID STOP VENT

P.O. Box 6358, Santa Rosa, CA 95406 (707) 544-2706 www.airmonitor.com amcsales@airmonitor.com

