


**SUBMITTAL SHEET**

# MASS-tron II

## ULTRA-LOW RANGE DIFFERENTIAL PRESSURE/ FLOW TRANSMITTER

<b>OPTIONS</b>																												
<input type="checkbox"/> Alarms or <input type="checkbox"/> AUTO-purge Mgmt <input type="checkbox"/> Auxiliary Output <input type="checkbox"/> Terminal Cover/Conduit Connection	<b>Special Functions</b> <input type="checkbox"/> % Deviation <input type="checkbox"/> Summed Flow <input type="checkbox"/> Averaged Flow <input type="checkbox"/> Differential Flow <input type="checkbox"/> Low Select <input type="checkbox"/> High Select	<b>Power</b> <input type="checkbox"/> 24VAC <input type="checkbox"/> 20-40VDC <input type="checkbox"/> 120VACI (via external transformer)	<b>Certification</b> <input type="checkbox"/> Standard <input type="checkbox"/> NIST Traceable	<b>Network</b> <input type="checkbox"/> None (std) <input type="checkbox"/> Modbus TCP/IP over Ethernet <input type="checkbox"/> LonWorks																								
<b>PERFORMANCE SPECIFICATIONS</b>																												
<b>Accuracy.</b> ±0.1% of Natural Span, including non-linearity, hysteresis, deadband, and non-repeatability.		<b>Mounting Position Effect.</b> None; corrected by AUTO-zero.																										
<b>Stability.</b> ±0.5% of Natural Span for six months.		<b>Power Consumption.</b>																										
<b>Temperature Effect</b> Zero. None; corrected by AUTO-zero. Span. 0.015% of Full Span/°F.		<table border="1" style="width: 100%; border-collapse: collapse; text-align: center;"> <thead> <tr> <th rowspan="2"></th> <th colspan="2">Standard</th> <th colspan="2">w/AUTO-purge</th> </tr> <tr> <th>In Rush</th> <th>Hold</th> <th>In Rush</th> <th>Hold</th> </tr> </thead> <tbody> <tr> <td>24VAC</td> <td>14.4VA</td> <td>14VA</td> <td>85VA</td> <td>73VA</td> </tr> <tr> <td>24VDC</td> <td>9.6W</td> <td>9.0W</td> <td>37W</td> <td>37W</td> </tr> <tr> <td>120VAC</td> <td>19.2VA</td> <td>18.67VA</td> <td>106VA</td> <td>92VA</td> </tr> </tbody> </table>				Standard		w/AUTO-purge		In Rush	Hold	In Rush	Hold	24VAC	14.4VA	14VA	85VA	73VA	24VDC	9.6W	9.0W	37W	37W	120VAC	19.2VA	18.67VA	106VA	92VA
	Standard		w/AUTO-purge																									
	In Rush	Hold	In Rush	Hold																								
24VAC	14.4VA	14VA	85VA	73VA																								
24VDC	9.6W	9.0W	37W	37W																								
120VAC	19.2VA	18.67VA	106VA	92VA																								
<b>Transducer Response Time.</b> 0.5 second to reach 98% of a step change.																												
<b>FUNCTIONAL SPECIFICATIONS</b>																												
<b>Digital Outputs.</b> Dual form C dry contacts and dual Form A dry contacts rated for 3 amps at 24VAC/VDC are used for optional High/Low alarms or AUTO-purge activation & acknowledgment.		<b>Automatic Zeroing.</b> Accuracy. Within 0.1% of calibrated span. Frequency. Every 1 to 24 hours on 1 hour intervals.																										
<b>Digital Inputs.</b> Dry contact for AUTO-purge external start command.		<b>Overpressure and Static Pressure Limit.</b> 25 psig.																										
<b>Analog Outputs.</b> Four outputs are individually configurable via jumper for 0-5VDC, 0-10VDC, or 4-20mADC.		<b>Circuit Protection.</b> Power input is isolated, fused and reverse polarity protected.																										
<b>Analog Inputs.</b> Dual inputs are field configurable via jumper for 0-5VDC, 0-10VDC, or 4-20mADC. One is reserved for temperature input; the other for use with optional special function.		<b>Span and Zero Adjustment.</b> Digital, via internally located push-buttons.																										
<b>AUTO-purge Management.</b> AUTO-purge cycle is initiated via an external dry contact input, or via an internal timer with field selectable frequencies of 1 to 24 hours, in 1 hour increments. Three internal relays provide purge activation & acknowledgment.		<b>Displays.</b> Standard 5 line x 20 character backlit graphical LCD provides five lines of data display. LED's indicate AUTO-zero in progress, CPU activated, AUTO-zero over-ranged, AUTO-purge in progress, and auxiliary alarm "on" status.																										
<b>Power Supply.</b> Standard 24VAC (20-28VAC) or 24VDC (20-40VDC), with automatic selection. Optional 120VAC (100-132 VAC), via external transformer.		<b>Temperature Compensation Selection.</b> Push-button selection of linearized or non-linear input. Choice of thermocouple (Type E, K, J, and T) or 100 ohm platinum RTD temperature sensor type.																										
<b>Low Pass Filtration.</b> Response time to reach 98% of a step change is adjustable from 2.0 to 250.0 seconds.		<b>Pressure Compensation.</b> Absolute pressure (atmosphere or duct static), up to 60"Hg.																										
		<b>Humidity Limits.</b> 0-95% RH, non-condensing.																										
		<b>Temperature Limits.</b> -20°F to 180°F Storage. +40°F to 140°F Operating.																										



AIR MONITOR CORPORATION